



Mike DeWine, Governor
Jon Husted, Lt. Governor
Laurie A. Stevenson, Director

NOTICE OF VIOLATION – ACTION REQUIRED

January 14, 2019

RE: WELLSTON VILLAGE PWS
NOV
Drinking Water Program
JACKSON County
PWS ID: OH4001912

CERTIFIED MAIL

91 7108 2133 3931 0972 3523

ADAM PETERS
WELLSTON VILLAGE PWS
203 EAST BROADWAY
WELLSTON, OH 45692

Subject: Violation of Maximum Contaminant Level for TOTAL HALOACETIC ACIDS (HAA5)

WELLSTON VILLAGE PWS is in violation for exceeding the maximum contaminant level (MCL) standard of 0.060 mg/L as established in the Ohio Administrative Code (OAC) section 3745-81 for TOTAL HALOACETIC ACIDS (HAA5). Compliance with the MCL is based on a locational running annual average (LRAA). The LRAA for TOTAL HALOACETIC ACIDS (HAA5) during the Fourth Quarter of 2018 time period is 0.061 mg/L at location DS201.

To address the MCL violation, WELLSTON VILLAGE PWS is required to take the following actions:

1. Notify your customers within 30 days using the enclosed instructions and public notice.
2. Complete and send a verification form with a copy of the public notice to the mailing address below within ten days after issuance.
3. Perform quarterly monitoring for TOTAL HALOACETIC ACIDS (HAA5) according to your most recent monitoring schedule.
4. Consult with your Ohio EPA district representative to discuss your options for coming into compliance and establishing a compliance schedule or comply with any previously issued enforcement action.
5. For a community water system, include in the Consumer Confidence Report (CCR) a clear explanation of the violation including the length of the violation, the potential adverse health effects, and actions taken by the system to address the violation. The mandatory health effects language for the particular contaminant is specified in the appendix to OAC section 3745-96-02.

Your prompt attention to this matter is greatly appreciated. Continued noncompliance may lead to additional enforcement actions. If you have any questions or wish to change the public notice, please call me at (614) 644-2752.

Sincerely,

Sara J. Starr (sara.starr@epa.ohio.gov)
Compliance Assurance Section
Division of Drinking and Ground Waters

Enclosure: Public Notice; Public Notice Instructions and Verification Form
cc: JACKSON County Health Department
ec: SEDO DOCC, DDAGW